



NOTES:

1. SAMPLE POINT STATIONS SHALL BE LOCATED AT ALL INTERCONNECTS, ENTRANCE TO GATED COMMUNITIES AND EVERY 3,000 LINEAR FEET ON ANY TRUNK/TRANSMISSION WATER MAIN. LOCATION TO BE DETERMINED BY SEMINOLE COUNTY WATER OPERATIONS GROUP.
2. SEE TYPICAL METER SERVICE CONNECTION DETAIL AND ADAPT TO 3/4" INLET.

SAMPLE POINT STATION